

CORRIGENDUM-II

Subject:-Dismantling of Old lifts & Supply, installation, Testing and commissioning of 3 Nos. of Lifts at IG ESIC Hospital Jhilimil, New Delhi.

1. Reference **NIT No. : W/11/113(Jhilimil)/SR/2018/PMD** with date of opening of e-Bid 28.02.19 and date of closing 25.03.2019.
2. Amendment / clarifications are as follows:

Amendment No.	Page No. / Location	Amendments/ Clarifications
1	P-91 / Sub Head 1(I) i) Speed and P-72/ Annexure-1, Speed	May be read as 1 Mps in place of 0.75 Mps
2	P-72/ Annexure-I, Car entrance	May be read as "Central opening sliding SS Door scratch proof with Suitable fire rating as per CPWD Specifications" in place of Central opening sliding SS Door (scratch proof) with Laminated Toughened glass panel 8mm thick.
3	P-67/ 4.1 Installation of lift machine	May be read as "Lift is machine room type and lift

machine may be mounted in machine room” in place of lift machine shall be mounted on the guide rail in the lift machine room.

- | | | |
|---|---|---|
| 4 | P-24/ Milestone of clause 5 | No Change |
| 5 | P-92/Sub Head II | No Change in Sub head – II but any other work apart from the BOQ will be taken care by ESIC. |
| 6 | P-68/Technical Specification Clause 6.4 | No Change, as fire rating of door already specified in clause 6.4 of Technical specifications of tender documents.
Added “The liability of fire rating test lies with manufacturing agency” |
| 7 | P-72/Annexure-I, Door Safety Mechanical and infrared door Protection system upto full Door height | No Change |
| 8 | P-30/Terms of Payment 3.0 | May be read as
3.1) 80% after initial inspection and delivery at site in good condition on pro |

rata basis in place of 70% after initial inspection and delivery at site in good condition of pro rata basis.

3.2) 10% after the completion of installation in all respect on pro rata basis after satisfactory testing by concerned inspecting authority of Delhi NCT in place of 20 % after the completion of installation in all respect on pro rata basis after satisfactory testing by concerned inspecting authority of Delhi NCT.

3.3) No Change

-
- 1. All other details/conditions will remain unchanged.**
 - 2. This amendment shall form part of the tender documents and shall be returned along with tender documents duly signed.**
 - 3. This amendment shall consist of page no. 96 to 98.**

khah
14/5/19

Assistant Director (Const.)