

Tender Inviting Authority: Additional Commissioner & Regional Director, ESIC Regional Office Faridabad

Name of Work: SPECIAL REPAIR WORKS TO EXISTING FIRE SUPPRESSION SYSTEM INSTALLED AT ESIC MH GURUGRAM INCLUDING SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF COMPLETE FIRE HYDRANT LINE AND FIRE ALARM SYSTEM WITH COMPLETE FINISHING

Contract No: 13/w/13/13/03/2008/Const.

Name of the Bidder/ Bidding Firm / Company :								
PRICE SCHEDULE								
NUMBER #	TEXT #	TEXT #	NUMBER #	TEXT #	NUMBER	NUMBER #	NUMBER #	TEXT #
Sl. No.	Item Description	Item Code / Make	Quantity	Units	Estimated Rate in Rs. P	BASIC RATE In Figures To be entered by the Bidder in Rs. P	TOTAL AMOUNT Without Taxes in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	6	13	53	55
1	Providing laying, testing & commissioning of 'C' class heavy duty MS Pipe conforming to IS 1239/3589 i/c fittings like elbows, tees, flanges, tapers, nuts bolts, gaskets etc. in ground including welding, excavation & providing cement concrete blocks as supports, anticorrosive treatment with oaltar/asphalt tape as per IS 10221, refilling the trench etc. of following sizes complete as required-150 mm dia	item1	1000	Mtr.	0.00			

2	Providing, laying, testing & commissioning of 'C' class heavy duty MS pipe conforming to IS 3589/IS 1239 including Welding, fittings like elbows, tees, flanges, tapers, nuts bolts, gaskets etc. and fixing the pipe on the wall/ceiling with suitable clamp/support frame and painting with two or more coats of synthetic enamel paint of required shade complete as required : 100 mm dia	item2	500	Mtr.	0.00			
3	Supplying, fixing, testing and commissioning of butterfly valve of PN 1.6 rating with bronze/gunmetal seat duly ISI marked complete with nuts, bolts, washers, gaskets conforming to IS 13095 of following sizes as required 80 mm dia	item3	2	Set	0.00			
4	100 mm dia	item4	2	Set	0.00			
5	150 mm Dia	item5	4	Set	0.00			
6	Supplying and fixing first-aid Hose Reel with MS construction spray painted in post office red, conforming to IS 884 complete with the following as required. 20 mm nominal internal dia water hose thermoplastic (Textile reinforced)	item6	10	Set	0.00			

7	Supplying & fixing 63 mm dia gun metal short branch pipe with 20 mm nominal internal diameter size nozzle conforming to IS 903 suitable for instantaneous connection to interconnect hose pipe coupling as required :- Gun Metal	item7	10	Nos.	0.00			
8	Supplying and fixing of fire brigade connection of cast iron body with gun metal male instantaneous inlet couplings complete with cap and chain as reqd. for suitable dia MS pipe connection conforming to IS 904 as required : 4 way - 150 mm dia M.S. Pipe	item8	1	Nos.	0.00			
9	Fire Hydrant single outlet gunmetal NB inlet brass spindle 63mm female instantaneous/outlet with PVC blank cap and GI chain as per IS:5290 (ISI Marked) Single head gunmetal hydrant valve	item9	10	Nos.	0.00			

10	Supplying and fixing 63 mm dia, 15 m long RRL hose pipe with 63 mm dia male and female couplings duly bound with GI wire, rivets etc. conforming to IS 636 (type-A) as required:- Gun Metal	item10	12	Nos.	0.00			
11	Providing, installation, testing and commissioning of non-return valve of following sizes confirming to IS: 5312 complete with rubber gasket, GI bolts, nuts, washers etc.as required :- 80 mm Dia	item11	1	Set	0.00			
12	100 mm dia	item12	2	Set	0.00			
13	150 mm Dia	item13	2	Set	0.00			
14	Metal Primer (U.G.)	item14	35	litre	0.00			
15	Roofing paint for iron sheets in red c	item15	35	litre	0.00			
16	Brass Set Up Nozzle of Hose Reel	item16	27	Nos.	0.00			
17	Pressure Guage 150 mm	item17	5	Nos.	0.00			
18	Pressure Guage 100 mm	item18	5	Nos.	0.00			
19	Repairing of Air Vessel with air release valve on top and flanged connection to riser, drain arrangement with gun metal wheel valve with required accessories, pressure gauge and painting with synthetic enamel paint of approved shade as required.	item19	3	Nos.	0.00			

20	Repairing & servicing of 2 nos fire pumps (Jockey & main hydrant) with all electromechanical parts	item20	2	Nos.	0.00			
21	Supply of new MS Hose Box (Two Door) of Size: 750 mm X 600 mm X 250 mm	item21	8	Nos.	0.00			
22	Reparing of FHC door with New Glass with lock	item22	11	Nos.	0.00			
23	Supplying, installation, testing & commissioning of heat detector operating at 54°C/57°C with rate of rise cum fixed temperature (dual thermistor) type with mounting base complete with all connection etc. as required.	item23	200	Nos.	0.00			
24	Supplying, installation, testing & commissioning of smoke detector with builtin LED and mounting base complete with all connections etc. as required	item24	250	Nos.	0.00			
25	Supplying, installation, testing & commissioning of manual call boxes of MS construction in surface/recess with stainless steel chain & hammer assembly complete with glass and push button etc. as required	item25	25	Nos.	0.00			

26	Supplying, installation, testing & commissioning response indicator on surface/recess MS box having two LEDs metallic cover complete with all connections etc. as required.	item26	200	Nos.	0.00			
27	Repairing of 2 Nos. Repeater Panel (Agni Make) with 4 Nos.7 AH 12V Batteries.	item27	2	Nos.	0.00			
28	Repairing of 1 No Fire conventional indication panel (Agni Make) with 2Nos. 7 AH 12V Batteries loop card, switches,Display, etc.	item28	1	Nos.	0.00			
29	Supplying, installation, testing & commissioning fire alarm sounder with facility to make announcement, mounted in M.S. box (16 SWG) with hinged cover plate & suitable for operation with amplifier i/c line matching transformer etc. complete as required.	item29	25	Nos.	0.00			
30	1.5 sq. mm ISI marked, FRLS PVC insulated, single core copper conductor cable	item30	1000	Metre	0.00			
31	20 mm dia. ISI marked, PVC conduit	item31	1000	Metre	0.00			
<b>Total in Figures</b>								
<b>Quoted Rate in Figures</b>				<b>Select</b>				
<b>Quoted Rate in Words</b>								